

DRAWING NO. 19

3 Storey Property
 GF - Commercial
 FF - 2 x SC Flatlets
 SF - 2 x SC Flatlets

January 2009













Provide 60 min fire resisting separation to commercial premises including stairway

GROUND FLOOR
 COMMERCIAL

FIRST FLOOR
 RESIDENTIAL

SECOND FLOOR
 RESIDENTIAL

KEY

-  Control and indicator panel linked to whole house system
-  Manual call point linked to whole house system
-  Smoke detector linked to whole house system
-  Heat detector linked to whole house system
-  Sounder linked to whole house system
-  Emergency lighting
-  Smoke alarm with internal sounder—not linked to whole house system
-  Optional heat alarm — with internal sounder not linked to whole house system
-  FD30S fire door
-  30 minutes fire resistance
-  60 minutes fire resistance
-  Self closing device

